

UKCA DECLARATION OF CONFORMITY

Product designation:
Switch-disconnectors with fuses
Switch-disconnectors (without fuses) and accessories

Issued by:
Wöhner GmbH & Co. KG
Mönchrödener Str. 10
96472 Rödental, Germany

The above mentioned products conform with the basic safety requirements of the following UK Regulations:

Number: Electrical Equipment (Safety) Regulations 2016
(S.I. 2016/1101)

Text: Electrical Equipment (Safety) Regulations
Directive on the harmonisation of the laws of the Member States relating to the making available on the market of electrical equipment designed for use within certain voltage limits.


The conformity is approved by the application of the following standards considering the scope of application and the national installation regulations:

Harmonised European standards:
EN 60947-1:2007 + A1:2011 + A2:2014
EN 60947-3:2009 + A1:2012 + A2:2015

IEC standards:
IEC 60947-1:2007 + A1:2010 + A2:2014
IEC 60947-3:2008 + A1:2012 + A2:2015

BS standards:
BS EN IEC 60947-1:2007 + A2:2014
BS EN IEC 60947-3:2009 + A2:2015

UKCA marking on packaging since: 2021



**WÖHNER
TEST LABORATORY**

Rödental, 11. April 2022


Philipp Steinberger
Chief Executive Officer


Holger Schulte
Corporate Technology Management

Please note:
This certificate refers to the production status of the mentioned products at the time of issue. It is based on a design evaluation respecting the valid standards. It is also based on our experience with similar

products. The rated values are valid for one single device in free air. In accordance with the exact application conditions, system-dependent reduction factors shall be provided. For the use of our products DIN EN 61439-1 is to be applied in the currently

valid version. Furthermore, the indications in our product manual are to be observed. A test regarding the exact conditions of use would need to be ordered specially. This certificate will not be updated after future changes in design or technology.