

| Schaltgerät | A | B | C | D | E _o * | E _u ** | |
|-------------|---|-----|-----|----|------------------|-------------------|----|
| 32 016 | Moeller NZM7 | 190 | 106 | 35 | – | 15 | 10 |
| 32 109 | Siemens 3VL1, 3VL2 | 172 | 108 | 29 | – | –6 | – |
| 32 110 | Siemens 3VL3 | 172 | 108 | 26 | – | 15 | – |
| 32 137 | AB 140U-J | 190 | 106 | 35 | – | 18 | 10 |
| 32 138 | AB 140U-L | 270 | 140 | 35 | – | 11 | 12 |
| 32 140 | Moeller NZM2-XKR4 | 190 | 106 | 35 | – | 22 | 2 |
| 32 148 | ABB T-max5 | 270 | 140 | 52 | 325 | 24 | – |
| 32 154 | ABB T-max4 | 320 | 110 | 52 | 325 | 24 | – |
| 32 156 | Merlin NS250, GE FD 250 | 190 | 106 | 35 | – | 12 | 12 |
| 32 157 | Merlin NS630 | 270 | 140 | 35 | – | 12 | 12 |
| 32 170 | Moeller NZM3-XKR130 | 270 | 140 | 35 | 280 | 22 | – |
| 32 226 | Siemens S3 | 182 | 70 | 26 | – | 22 | – |
| 32 549 | AB 140-CMN | 200 | 90 | 50 | – | 11 | – |
| 32 570 | Moeller NZM1 | 200 | 90 | 38 | – | 17 | – |
| 32 575 | ABB T-max1, T-max2, GE FD 160, Merlin Gerin NS80 | 200 | 90 | 26 | – | 10–20 | – |
| 32 578 | Siemens 3VL2, 3VL3, 4-pol. | 240 | 140 | 35 | – | 16 | – |
| 32 579 | Siemens 3VL4, 4-pol. | 300 | 185 | 35 | – | 15 | – |
| 32 580 | Moeller NZM2-XKR4, 4-pol. | 240 | 140 | 35 | – | 2 | – |
| 32 581 | Moeller NZM3-XKR130, 4-pol. | 300 | 185 | 35 | – | 15 | – |
| 32 582 | Merlin NS250, 4-pol. | 240 | 140 | 35 | – | –8 | – |
| 32 583 | Merlin NS630, 4-pol. | 300 | 185 | 35 | – | 15 | – |
| 32 584 | ABB T-max4, 4-pol. | 240 | 140 | 35 | – | 7 | – |
| 32 585 | ABB T-max5, 4-pol. | 300 | 185 | 35 | 325 | 15 | – |
| 32 975 | Siemens 3VL4 | 295 | 140 | 55 | – | 6 | 19 |
| 32 976 | Siemens 3VL1 UL | 190 | 106 | 53 | – | 8 | 15 |
| 32 977 | Siemens 3VL2, 3VL3 UL | 190 | 106 | 53 | – | 16 | 7 |
| 32 980 | Siemens 3VL5 | 325 | 184 | 55 | – | –7 | – |

* E_o Versatz Schaltermitte bei Verbindung oben

** E_u Versatz Schaltermitte bei Verbindung unten

